



May 13, 2014

To: Potential Bidders

From: Lisa Hall, Buyer

Subject: Tompkins County Request for Bids – Truss and Fabric Building

ADDENDUM 2

Please see below for clarifications and additions to the original specifications for the above referenced bid. All other terms and conditions, including the bid due date of **May 27, 2014** and time, **11:30 a.m.** remain unchanged.

Clarification – Scope of Services, Section 2.0, General Requirements, #2:

- The building foundation design and construction will be procured by the site owner following the award of bids by Tompkins County. The information requested with the bid is to identify the foundation type recommended by each vendor.
- An elevation plot plan is not yet available and will be prepared as part of the site design and foundation systems to be procured by the site owner. A general site plan showing the building location and general topography is attached.
- Fabric roof must conform to NFPA 701 specifications, per NYS Building Code.
- The following design loads shall apply to the proposed building:
 - Ground snow: 40 psf
 - Snow exposure factor: 1.0
 - Thermal factor: 1.2
 - Snow importance factor: 1.0
 - Basic wind speed: 90 mph
 - Wind importance factor: 1.0
 - Wind exposure: C
 - Seismic importance factor: 1.0
 - Site class: D
 - Sds: 0.172
 - Sd1: 0.089
 - Seismic design category: B
- Clearance height at the center of the building shall be a minimum of 27 feet
- The height of the wall the building will be mounted on is 4 feet
- The building shall be open on both ends for access therefore requiring no additional ventilation

Add – Scope of Services, Section 2.o, General Requirements:

8. The timeframe for the build shall be within 8 weeks after award notification.
9. Site visits may be arranged with Leo Riley, (607) 273-6632.

Questions regarding this Addendum or the original specifications shall be directed to Lisa Hall, lhall@tompkins-co.org.

Sincerely,

Lisa M. Hall, Buyer